
State Water Resources Control Board

January 31, 2022

PWS No. 3410007

Hon. Russell Hom
Presiding Judge
Sacramento County Superior Court
720 9th St.
Sacramento, CA 95814

DEL PASO MANOR WATER DISTRICT PUBLIC WATER SYSTEM (PWS No. 3410007)

NOVEMBER 5, 2021, GRAND JURY REPORT

The California State Water Resources Control Board, Division of Drinking Water (Division) received a report prepared by the Sacramento County Grand Jury regarding Del Paso Manor Water District (DPMWD) public water system (PWS No. 3410007) dated November 5, 2021. This report has been reviewed by Division staff. The following clarifications and comments are presented for your records.

Operation of Well 8 (third paragraph on page 13 of the report)

According to the operation records provided by the DPMWD, at the time the August 23, 2019, Notice of Violation (NOV) was issued, Well 8 had not been in services since November 2018. The NOV was issued in accordance with Section 64445.1, Article 5.5, Chapter 15, Division 4, Title 22 of the California Code of Regulations (CCR). The records show that after the NOV was issued Well 8 was operated at the monthly quantities below. The Division is not aware of the reasons why Well 8 was operated following the issuance of the NOV.

- September 2019 – 3.387 million gallons (MG) or 6.7% of total water system monthly production.
- October 2019 – 12.942 MG or 29.0% of total water system monthly production.
- March 2021 – 200 gallons.

E. JOAQUIN ESQUIVEL, CHAIR | EILEEN SOBECK, EXECUTIVE DIRECTOR

Recommendations R4 and R5 (page 15 of the report)

Sacramento District has always been available to provide clarification(s) regarding drinking water regulations and statutes – including public notification. All public water systems including DPMWD are encouraged to contact the Sacramento District for clarification(s).

If you have any questions, or if I can be of any assistance, please do not hesitate to contact me at (916) 445-5285, or by email at: Ali.rezvani@waterboards.ca.gov.

Sincerely,



Ali R. Rezvani, P.E.
Sacramento District Engineer
Division of Drinking Water
STATE WATER RESOURCES CONTROL BOARD

Enclosures,

cc. Kim Hanagan, P. E. Chief – Northern California Section, DDW, SWRCB

Ginger Derham
Jury Commissioner
DerhamG@saccourt.ca.gov

Ms. Erendira Tapia-Bouthillier
Grand Jury
TapiaE@saccourt.ca.gov